

VILLAGE DISTRICT CONSULTANT

DATE: November 9, 2016

APPLICANT: 22 Catoonah Street

Farmer's Market Co-op

MEETING LOCATION: Town Hall Annex
Back Lower Level Conference Room

VDC MEMBERS:

(Place check next to those who attended)

☒ S. Benton ☐ J. Clements ☒ J. Goldfluss ☐ J. Heyman
☐ J. Hupy ☒ J. Kinnear ☒ L. Lavelle ☒ G. Lounsbury

ALSO PRESENT: Sandy Sutula

APPLICATION: ☐ Special Permit – *New Building* ☐ Site Plan Approval
☐ Special Permit – *Addition* ☒ Sign
☐ Exterior Renovation ☐ Other: _____

ACTION: ☒ VDC recommends design approval as noted
☐ VDC does not recommend design approval
☐ Additional design studies/information requested
☐ Other: _____

COMMENTS, EXCEPTIONS AND/OR RECOMMENDED CONDITIONS

The VDC recommends approval of the application as submitted with the following comment:


- 1) The paint used on the sign is translucent and may require repainting with a more opaque paint for better visibility.
- 2) If lights are installed this will require an additional review by the VDC.

Vote

For approval of recommendations: 5

Against approval of recommendations: 0

BY: John Kinnear



ARCHITECTURAL ADVISORY COMMITTEE

DATE: November 9, 2016

APPLICANT: 258 Main Street

Aldrich Contemporary Art Museum

MEETING LOCATION: Town Hall Annex
Back Lower Level Conference Room

AAC MEMBERS:

(Place check next to those who attended)

<input checked="" type="checkbox"/> S. Benton	<input type="checkbox"/> J. Clements	<input checked="" type="checkbox"/> J. Goldfluss	<input type="checkbox"/> J. Heyman
<input type="checkbox"/> J. Hupy	<input checked="" type="checkbox"/> J. Kinnear	<input checked="" type="checkbox"/> L. Lavelle	<input checked="" type="checkbox"/> G. Lounsbury

ALSO PRESENT: Richard Klein

APPLICATION: ☐ Special Permit – *New Building* ☐ Site Plan Approval
☐ Special Permit – *Addition* ☒ Sign
☐ Exterior Renovation ☐ Other: _____

ACTION: ☒ AAC recommends design approval as noted
☐ AAC does not recommend design approval
☐ Additional design studies/information requested
☐ Other: _____

COMMENTS, EXCEPTIONS AND/OR RECOMMENDED CONDITIONS

The AAC recommends approval of the sign as submitted with the following comments:

- 1) The museum plans to install ground lights aimed at the sign from both sides. These lights must be shielded, the LED light temperature should be 3,000K, and the lights must be dimmable so as not to be too bright.

Vote

For approval of recommendations: 5

Against approval of recommendations: 0

BY: John Kinnear