



ARCHITECTURAL ADVISORY COMMITTEE

DATE: June 13, 2017

APPLICANT: 872 Ethan Allen Highway

Prime Storage Group

MEETING LOCATION: Town Hall Annex
Back Lower Level Conference Room

AAC MEMBERS:

(Place check next to those who attended)

| | | | |
|------------------------------------|--|---------------------------------------|--|
| <input type="checkbox"/> S. Benton | <input type="checkbox"/> J. Clements | <input type="checkbox"/> J. Goldfluss | <input checked="" type="checkbox"/> J. Heyman |
| <input type="checkbox"/> J. Hupy | <input checked="" type="checkbox"/> J. Kinnear | <input type="checkbox"/> L. Lavelle | <input checked="" type="checkbox"/> G. Lounsbury |

ALSO PRESENT: Brenda Freeman

APPLICATION:

| | |
|---|---|
| <input type="checkbox"/> Special Permit – <i>New Building</i> | <input type="checkbox"/> Site Plan Approval |
| <input type="checkbox"/> Special Permit – <i>Addition</i> | <input checked="" type="checkbox"/> Sign |
| <input type="checkbox"/> Exterior Renovation | <input type="checkbox"/> Other: _____ |

ACTION:

| |
|---|
| <input checked="" type="checkbox"/> AAC recommends design approval as noted |
| <input type="checkbox"/> AAC does not recommend design approval |
| <input type="checkbox"/> Additional design studies/information requested |
| <input type="checkbox"/> Other: _____ |

COMMENTS, EXCEPTIONS AND/OR RECOMMENDED CONDITIONS

The AAC recommends approval of the size and graphics of the two signs – one pole-mounted on the existing pole, one on the building.

The building sign is going to be internally lit. The background must be opaque, and only allow light to pass through the lettering. The opaque interior panel should be on the drawing.

Vote

For approval of recommendations: 3

Against approval of recommendations: 0

BY: John Kinnear